

CERTIFICATE OF CONFORMITY

This Certificate is issued to

IZOPOLI YAPI ELEMENLARI TAAH SAN. VE. TIC. A.S.

Yumurtalik Serbest Bolgesi

3 No'lu Parsel, 01920

Ceyhan-Adana, Turkey

For Product Certification Scheme: Class 1

Product : Fire Rated Partition – Compartment Wall

Brand : IZOPOLI

Model : KS110CTF

Country of Origin : Turkey

Product Details : Cold Store Wall Panel
Thickness: 200mm
Integrity: 180 mins
Insulation: 60 mins

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

EN 1364-1: 2001

TEST REPORT(S)

92805/194237



Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No

FSP-2015-0277

Date of Issue

08/10/2015

Date of Expiry

07/10/2018



This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking SETSCO website at www.setsco.com.