



CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality,
hereby attests that the product(s):

FACTORY-MADE RIGID POLYURETHANE FOAM

(Details as per the attached Scope of Certification)

manufactured by:

KINGSPAN YAPI ELEMANLARI A.S. (ADANA)

Yumurtalik Serbest Bolgesi 3 No'Lu Parsel 01920 – Ceyhan/Adana Turkey

have been assessed in accordance with DCLD Document Ref. No. RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 13165:2012

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark to the above-mentioned product(s).


ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL12020169
Valid Until: 19 September 2017



Current Issue Date: 20 September 2016
Original Issue Date: 20 September 2012

The attached Scope of Certification bearing the same Certificate No. forms an integral part of this certificate.
This certificate is subject to the Terms and Conditions of the Product Certification System
and shall not be reproduced except in full.



**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL12020169**

Certificate Issued To: KINGSPAN YAPI ELEMANLARI A.S. (ADANA)
Yumurtalik Serbest Bolgesi 3 No'Lu Parsel 01920
– Ceyhan/Adana Turkey

Applicable Standard Specification: BS EN 13165:2012 –Thermal insulation products for buildings – Factory made rigid polyurethane foam (PUR) products - Specification

Applicable Specific Rules: RD-DP21-2124 (IC) “Specific Rules for Certification of Factory Made Rigid Polyurethane BS EN 13165:2012) Through Factory Assessment”.

S/N	Product Description	Brand Name	Product Details
1	Factory made rigid Polyisocyanurate (PIR) foam for Sandwich Panel (CFC Free)	KINGSPAN “IPN FIRESAFE”	PIR Thermal Insulation Foam Nominal Thickness range – 40mm to 220mm; Length – 1000mm to 12000mm; Width – 900mm to 1200 mm; Apparent Density (min) 32 kg/m ³ ; Thermal conductivity (max) initial value - 0.0259 W/(m*K) and aged value - 0.0297 W/(m*K) @ 35C and 60% RH Code: PIR - EN 13165 – T2 - DS(TH)4 - CS(10/Y)100 – MU60-250 Manufactured with flat or corrugated metal sheet on both or either sides and kraft paper with or without aluminum foil facing.

NOTE 1: The above products shall bear the DCL Conformity Mark applied on each individual product.

NOTE 2: This certification covers only the PIR foam within the panel

NOTE 3: This document forms part of the Certificate of Product Conformity bearing the same certificate number

NOTE 4: CFC Free as per declaration from the company, in accordance with the Dubai Green Building Regulations and Specifications

NOTE 5: Reaction to fire meets Euro Class E Fire classification

NOTE 6: This supersedes the Scope of Certification issued on 20 September 2015

Original Issue Date : 20 September 2012
Current Issue Date : 20 September 2016
Valid Until : 19 September 2017


ARIF HUSAIN AL MARZOOQI
Head of Products Conformity Assessment Section
Dubai Central Laboratory Department