

بسم الله الرحمن الرحيم

DATE: 16-Dec-14 التاريخ
PERMIT # PS-167232-PA رقم الطلب



وزارة الداخلية
الإدارة العامة للدفاع المدني
إدارة الوقاية

TECHNICAL REPORT

التقرير الفني لمعدات الإطفاء والسلامة

PRODUCT:	BUILDING INSULATIONS-WALLS AND CEILINGS	المنتج:
----------	---	---------

PRODUCT APPLICATION:	PASSIVE FIRE PROTECTION SYSTEM	تصنيف المعدة:
----------------------	--------------------------------	---------------

APPLICANT / P.O. BOX	FTC QATAR	مقدم الطلب/صندوق البريد:
----------------------	-----------	--------------------------

MANUFACTURER / LOCATION:	IZOPOLI YAPI ELEMANLARI TAAH SAN VE TIC AS / TURKEY	الشركة المصنعة:
--------------------------	---	-----------------

PRODUCT/MODEL	<p>BUILDING INSULATIONS-WALLS AND CEILINGS MODEL: "KS110CTF" (Class I) CAMLOCK COLD STORE PANEL Metal-Faced with Combustible Core minimum 0.016 in (0.40 mm) thick interior and exterior coated (optional) galvanized steel or stainless steel facers with a 1.6-7.9 in. (40-200 mm) thick IPN core foam system. Panels are 43.3 in (1100 mm) wide. Assembly of interior corners are finished with 76 mm (3.0 in) by 76 mm (3.0 in) by 0.6 mm (0.02 in) steel angle flashing fastened 300 mm (11.8 in) on center.</p> <p>Note: The listed assemblies are not intended as long-term fire walls or barriers since fire endurance was not evaluated.</p> <p>STD: FM Approvals Standard 4880 (2005)</p>	قائمة المنتجات:
---------------	---	-----------------

3RD PARTY CERTIFICATE / APPROVAL	FM APPROVED	شهادات المختبرات المساندة(من هيئات معتمدة):
----------------------------------	-------------	--

RECOMMENDATIONS التوصيات

The QCDD has reviewed the submission of the above mentioned applicant and finds NO OBJECTION to the sale and use of the Fire Safety Product/ Equipment herein stated, whose authenticity was supported by applicant's submission of its 3rd Party test/approval certifications. The authority of this approval extends up to the installation of this product which shall be performed only by competent person/technician duly certified by QCDD.

The product shall bear the mark of the certifying body and shall be verified by the engineer prior to installation.

This product approval is valid up to two (2) years from the date of issue.

MANUFACTURER NAME/LOGO & FM MARK

ENGINEERS المهندسين OFFICERS الضابط المختص

بسم الله الرحمن الرحيم

التاريخ: 21/12/2014
الموافق: 29/02/1436
رقم الطلب: 167232



127

وزارة الداخلية
الإدارة العامة للدفاع المدني
إدارة الوقاية

شهادة الإدارة العامة للدفاع المدني

23023100020001

شهادة عدم ممانعة استيراد معدات و أجهزة و مواد نظلم
الوقاية و مكافحة للحريق

نوع الشهادة

رقم الشهادة

2014/12/16

التاريخ

37846

رقم رخصة البناء

اسم المرخص له اشرف عبدالرحيم محمد ابو عيسى وشركاه

0

اسم المالك

38190

رقم السجل التجاري

اف تي سي - قطر

الاسم التجاري

1

رقم الوحدة

44466111

هاتف المكتب

55516682

الهاتف الجوال

44466112

رقم الفاكس

صندوق البريد

ashraf@bluesalon.com

البريد الالكتروني

اسم
الشارع: مسجيم بن حمد

رقم الشارع: 231

رقم المنطقة: 23

رقم المبنى:


رقم قطعة
الأرض: 2

تفاصيل الشهادة

تمت الموافقة على المنتج (BUILDING INSULATIONS-WALLS AND CEILINGS) وذلك حسب التقرير الفني الصادر بتاريخ 2014/12/16
والمرافق طيه صورته منه

ملاحظة :-

(يرجى الإطلاع على الإشتراطات في خلف الشهادة والإلتزام بها)



توقيع مدير إدارة الوقاية: 15

الإدارة العامة للدفاع المدني *

تاريخ انتهاء الشهادة 2016/12/20

تاريخ إصدار الشهادة 2014/12/21

توقيع الضابط المختص:
إدارة الوقاية